

# Radon Testing Results - Four Rivers Comm

## Action Level is 4.0 pCi/L

Site Name	Building Name	Room Description (per floor plan)	Kit serial #
Four Rivers Community School	Jr. Prep Building	Uniform closet	8589169
Four Rivers Community School	Jr. Prep Building	SW Classroom	8589170
Four Rivers Community School	Main Building	1st Floor-mech. closet	8589172
Four Rivers Community School	Main Building	Supt. Office	8589173
Four Rivers Community School	Main Building	Workroom	8589174
Four Rivers Community School	Main Building	1st floor NW classroom	8589175

# Community School

Date sampled	Type of test	Results (pCi/L)
4/9/18	Detector kit	1.7
4/9/18	Detector kit	1.3
4/9/18	Detector kit	1.2
4/9/18	Detector kit	1.0
4/9/18	Detector kit	1.4
4/14/18	Detector kit	1.7